



ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - ०७

Date - ०१/०४/२०२५

FIRE SAFETY CERTIFICATE

Certified that the SARASWATI VIDYALAYA (name of the building or Premises) at Kavesar, Near Swastik Residency, G.B. Road, Thane. (w) 400615. (address) Comprised of Ground + 4th Floor owned / occupied by SARASWATI VIDYALAYA, Kavesar, Near Swastik Residency, G.B. Road, Thane. (w) (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 17/03/2025 (date of inspection) in the presence of Miss. Reshma Dhananjay Mali (CHINMAY ENTERPRISES Fire Protection & Safety Engineers) (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X/XII) With effect from 01.04.2025 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- | | | | |
|---------------------------|-------|-----------------------------------|-------|
| 1. Hydrant Valve | - Yes | 5. ABC Fire Extinguisher 6Kg Cap. | - Yes |
| 2. Hose Real Drum | - Yes | 6. Booster Pump 40 HP | - Yes |
| 3. Hose Box Complete | - Yes | 7. Booster Pump 5 HP | - Yes |
| 4. Fire Brigade NRV 2 Way | - Yes | | |

Issued on 01 / 04 / 2025 (date of issue) at Thane (place) by

Signature with seal: -----



Name : Mr. Girish. M. Zalke

Designation : Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane
Municipal Fire Brigade, Thane.

To

SARASWATI VIDYALAYA
Kavesar, Near Swastik Residency,
G.B. Road, Thane. (w) 400615.
(Name & Address of the Institution)

ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)